

# Bently Nevada 107770-03-02 Manual

|                |                               |
|----------------|-------------------------------|
| Brand          | Bently Nevada                 |
| Product Series | Sheet38                       |
| Product Type   | A or B (in compliance with EN |

## Description

Part Number: 107770-03-02

Model: Velocity Transducer Housing – CENELEC approved

Manufacturer: Bently Nevada

Condition: New & Original in Factory Packing

Factory Warranty: 12 Months

### Ordering Information

Model: 107770 - Velocity Transducer Housing – CENELEC approved

Mounting Thread Option:03 =1/2-14 NPT

Cable Exit Fitting Option:02= 1/2-14 NPT explosion-proof

This version is a combination of the 330500

Velomitor Sensor and a 21128 Housing preinstalled at the factory. It is also rated for

CENELEC Zone 1, Group IIC hazardous area

applications.

RoHS

RoHS Directive 2011/65/EU

### Hazardous Area Conditions of

Safe Use

ATEX/IECEX

### Zone 0/1:

Equipment must be connected to equipment, which meets the abovelisted entity

parameters.

The cables type A or B (in compliance with EN

60079-25) must respect the cable parameters

listed with the entity parameters.

### Zone 2:

The supply electrical parameters shall not

exceed the values mentioned in the tables

above.

